

Liberty


SALTASH TOWN COUNCIL  
SERVICE DELIVERY DEPARTMENT

IN SERVICE TESTING AND INSPECTION (PAT TESTING)

DATE: March 25  
ENGINEER'S NAME & SIGNATURE: Josh Floyd  
CONTACT INFORMATION: 01752 844846

TEST EQUIPMENT/MODEL: MEGGER PAT150R (131479)  
SERIAL NUMBER: SN 1003-428  
CALIBRATION DATE:

CUSTOMER'S NAME: SALTASH TOWN COUNCIL  
SITE ADDRESS:   
RESPONSIBLE PERSONS NAME: SINEAD BURROWS / RICHARD ENTICKNAP



| Item ID                     | Item Description          | Make And Model | Serial Number | Item Location | Class | Watts (W) | Rating (A) | Fuse Size | TEST              |                         |                               |                  |              | Test Engineers Comments: |
|-----------------------------|---------------------------|----------------|---------------|---------------|-------|-----------|------------|-----------|-------------------|-------------------------|-------------------------------|------------------|--------------|--------------------------|
|                             |                           |                |               |               |       |           |            |           | Visual Inspection | Earth Continuity (Ohms) | Insulation Resistance (Mohms) | Functional Check | Pass or Fail |                          |
| 001                         | Large white water kettle  | Swan           | SWU39         | Kitchen       | 1     | 1800      | 13         | 13        | Pass              | 0.10                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 2                           | —                         |                |               |               |       |           |            |           |                   |                         |                               |                  |              |                          |
| 3                           | Leakage Tester            | De 11          | SMP LS33      | Ground        | 1     | 100       | 5          | 5         | Pass              | 0.34                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 4                           | Leakage Monitor           | 11 Yama        | PL1750        | Ground        | 1     | 100       | 10         |           | Pass              | 0.57                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 5                           | White 4c extension        | Plasticity     | N/A           | Ground        | 18    | 13        | 13         | 13        | Pass              | 0.22                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 6                           | McAlister 12v             |                | 5164634       | Ground        | 2     | 100       | 1.1A       | N/A       | Pass              | 0.18                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 7                           | PL1750 Monitor            | 11 Yama        | N/A           | Ground        | 1     | 100       | 10         |           | Pass              | 0.34                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 8                           | Leakage Scanner           | Lihter         | N/A           | Ground        | 1     |           | 13         | 13        | Pass              | 0.10                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 9                           | Self Kiosk clock 1        | Smart Kiosk    | TN1740351     | Ground        | 1     | 100       | 5          | 5         | Pass              | 0.30                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 10                          | Self Kiosk clock 2        | Smart Kiosk    | TN1740354     | Ground        | 1     | 100       | 5          | 5         | Pass              | 0.24                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 11                          | Roll Luggage gender bench | Pull           | 418422        | Ground        | 1     | 130       | 5          | 5         | Pass              | 0.36                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 12                          | Canon C5550i instel       | Canon          | C5550i        | Ground        | 1     | 1700      | 13         | 13        | Pass              | 0.22                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 13                          | Long blue extension 4c    | Leitec         | N/A           | Ground        | 1     | 3100      | 13         | 13        | Pass              | 0.41                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 14                          | 2c white extension        | Altecstar      | N/A           | Ground        | 1     | 3100      | 13         | 13        | Pass              | 0.24                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 15                          | Samsung TV                | Samsung        | QE75Q6        | Ground        | 1     | 118       | 3          | 3         | Pass              | 0.10                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 16                          | Henry Hydraulic hoover    | Hydraulic      |               | Ground        | 2     | 610       | 13         | 13        | Pass              | 0.10                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| TOTAL NUMBER OF APPLIANCES: |                           |                |               |               |       |           |            |           |                   | 1                       |                               |                  |              |                          |

✓



Libraries

SALTASH TOWN COUNCIL  
SERVICE DELIVERY DEPARTMENT

## IN SERVICE TESTING AND INSPECTION (PAT TESTING)

|                              |              |
|------------------------------|--------------|
| DATE:                        | MARCH 25     |
| ENGINEER'S NAME & SIGNATURE: | Josh Floyd   |
| CONTACT INFORMATION          | 01752 844846 |

|                       |                        |
|-----------------------|------------------------|
| TEST EQUIPMENT/MODEL: | MEGER PATISOR (131479) |
| SERIAL NUMBER:        | SN 1003-428            |
| CALIBRATION DATE:     |                        |

|                           |                                    |
|---------------------------|------------------------------------|
| CUSTOMER'S NAME:          | SALTASH TOWN COUNCIL               |
| SITE ADDRESS:             |                                    |
| RESPONSIBLE PERSONS NAME: | SINEAD BURROWS / RICHARD ENTICKNAP |



| Item ID | Item Description          | Make And Model | Serial Number | Item Location | Class | Watts (W) | Rating (A) | Fuse Size | TEST              |                         |                               |                  |              | Test Engineers Comments: |
|---------|---------------------------|----------------|---------------|---------------|-------|-----------|------------|-----------|-------------------|-------------------------|-------------------------------|------------------|--------------|--------------------------|
|         |                           |                |               |               |       |           |            |           | Visual Inspection | Earth Continuity (Ohms) | Insulation Resistance (Mohms) | Functional Check | Pass or Fail |                          |
| 17      | HP L1730 monitor          | HP L1730       | 3CESS1356     | Reception     | 1     | 100       | 10         | 10        | Pass              | 0.58                    | 74444                         | Pass             | Pass         | Tested at 250v           |
| 18      | HP L1730 monitor          | HP L1730       | 3CESS1356     | Reception     | 1     | 130       | 5          | 5         | Pass              | 0.24                    | 74444                         | Pass             | Pass         | Tested at 250v           |
| 19      | HP L1730 monitor          | HP L1730       | 3CESS1356     | Reception     | 1     | 100       | 5          | 5         | Pass              | 0.61                    | 74444                         | Pass             | Pass         | Tested at 250v           |
| 20      | 4x extension lead with 1x | HP L1730       | 3CESS1356     | Reception     | 1     | 3100      | 13         | 13        | Pass              | 0.25                    | 74444                         | Pass             | Pass         | Tested at 500v           |
| 21      | HP L1730 monitor          | HP L1730       | 3CESS1356     | Reception     | 1     | 130       | 5          | 5         | Pass              | 70.24                   | 74444                         | Pass             | Pass         | Tested at 250v           |
| 22      | HP L1730 monitor          | HP L1730       | 3CESS1356     | Reception     | 1     | 100       | 5          | 5         | Pass              | 0.98                    | 74444                         | Pass             | Pass         | Tested at 250v           |
| 23      | 4x 50w extension lead     | HP L1730       | 3CESS1356     | Reception     | 1     | 3100      | 13         | 13        | Pass              | 0.27                    | 74444                         | Pass             | Pass         | Tested at 500v           |
| 24      | 4x 50w extension lead     | HP L1730       | 3CESS1356     | Reception     | 2     | 100       | 5          | 5         | Pass              | 0.20                    | 74444                         | Pass             | Pass         | Tested at 250v           |
| 25      | 4x 50w extension lead     | HP L1730       | 3CESS1356     | Reception     | 2     | 100       | 5          | 5         | Pass              | 0.10                    | 74444                         | Pass             | Pass         | Tested at 250v           |
| 26      | 4x 50w extension lead     | HP L1730       | 3CESS1356     | Reception     | 1     | 3100      | 13         | 13        | Pass              | 0.53                    | 74444                         | Pass             | Pass         | Tested at 250v           |
| 27      | 4x 50w extension lead     | HP L1730       | 3CESS1356     | Reception     | 2     | 100       | 5          | 5         | Pass              | 0.89                    | 74444                         | Pass             | Pass         | Tested at 250v           |
| 28      | 4x 50w extension lead     | HP L1730       | 3CESS1356     | Reception     | 1     | 100       | 10         | 10        | Pass              | 0.41                    | 74444                         | Pass             | Pass         | Tested at 250v           |
| 29      | 4x 50w extension lead     | HP L1730       | 3CESS1356     | Reception     | 1     | 100       | 10         | 10        | Pass              | 0.53                    | 74444                         | Pass             | Pass         | Tested at 250v           |
| 30      | 4x 50w extension lead     | HP L1730       | 3CESS1356     | Reception     | 1     | 100       | 10         | 10        | Pass              | 0.41                    | 74444                         | Pass             | Pass         | Tested at 250v           |
| 31      | 4x 50w extension lead     | HP L1730       | 3CESS1356     | Reception     | 1     | 3100      | 13         | 13        | Pass              | 0.45                    | 74444                         | Pass             | Pass         | Tested at 250v           |
| 32      | 4x 50w extension lead     | HP L1730       | 3CESS1356     | Reception     | 1     | 100       | 5          | 5         | Pass              | 0.90                    | 74444                         | Pass             | Pass         | Tested at 250v           |

TOTAL NUMBER OF APPLIANCES: [ ]





|                                      |                          |                   |               |               |       |           |            |           |                   | TEST                    |                               |                  |              |                          |
|--------------------------------------|--------------------------|-------------------|---------------|---------------|-------|-----------|------------|-----------|-------------------|-------------------------|-------------------------------|------------------|--------------|--------------------------|
| Item ID                              | Item Description         | Make And Model    | Serial Number | Item Location | Class | Watts (W) | Rating (A) | Fuse Size | Visual Inspection | Earth Continuity (Ohms) | Insulation Resistance (Mohms) | Functional Check | Pass or Fail | Test Engineers Comments: |
| 33                                   | Sunday PC Monitor        | Samsung LS17      | HAAK00000     | Ground        | I     | 100       | 10         | 10        | Pass              | 0.54                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 34                                   | Dell PC Tower Black      | Dell D811         | DS11002       | Ground        | I     | 100       | 5          | 5         | Pass              | 0.56                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 35                                   | LHP L1450E Screen        | LHP               | CNUGS340W     | Ground        | I     | 100       | 5          | 5         | Pass              | 0.70                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 36                                   | Bk 4G Black Extension    | Bk                | /             | Ground        | I     | 300       | 13         | 13        | Pass              | 0.34                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 37                                   | Bk 4G Black Extension    | Bk                | /             | Ground        | I     | 300       | 13         | 13        | Pass              | 0.42                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 38                                   | Dell PC Tower Black      | D115              | D115002       | Ground        | I     | 100       | 5          | 5         | Pass              | 0.67                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 39                                   | HP L1750 Screen          | HP                | CNUGS340W     | Ground        | I     | 100       | 5          | 5         | Pass              | 0.55                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 40                                   | Bk 4G Black Extension    | Bk                | /             | Ground        | I     | 300       | 13         | 13        | Pass              | 0.75                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 41                                   | Belkin 4G Long Extension | Belkin            | /             | Ground        | I     | 300       | 13         | 13        | Pass              | 0.26                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 42                                   | HP L1750 Monitor         | HP CNUGS340W/B3   | /             | Ground        | I     | 100       | 5          | 5         | Pass              | 0.64                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 43                                   | All PC Tower Black       | <del>Optima</del> | D115002       | Ground        | I     | 100       | 5          | 5         | Pass              | 0.36                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 44                                   | Bk 4G Extension Black    | Bk                | /             | Ground        | I     | 300       | 13         | 13        | Pass              | 0.75                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 45                                   | Vanna Black Monitor      | Vanna BT003       | V02LPS010     | Ground        | I     | 100       | 5          | 5         | Pass              | 0.41                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 46                                   | Dell PC Tower Black      | Dell D115002      | /             | Ground        | I     | 100       | 5          | 5         | Pass              | 0.48                    | 744.44                        | Pass             | Pass         | Tested at 250v           |
| 47                                   | PC Tower White extension | M-Extension       | N/A           | For Office    | I     |           |            |           |                   |                         |                               |                  |              |                          |
| TOTAL NUMBER OF APPLIANCES: [      ] |                          |                   |               |               |       |           |            |           |                   |                         |                               |                  |              |                          |



Liberty

SALTASH TOWN COUNCIL  
SERVICE DELIVERY DEPARTMENT

**IN SERVICE TESTING AND INSPECTION (PAT TESTING)**

DATE: MARCH 25

ENGINEERS NAME & SIGNATURE: \_\_\_\_\_


Josh Floyd

CONTACT INFORMATION

01752 844846

|                        |
|------------------------|
| TEST EQUIPMENT/MODEL:  |
| MEGGER PAT150R (13479) |
| SERIAL NUMBER:         |
| SN 1003-428            |
| CALIBRATION DATE:      |
|                        |

|                                    |
|------------------------------------|
| CUSTOMERS NAME:                    |
| SALTASH TOWN COUNCIL               |
| SITE ADDRESS:                      |
| RESPONSIBLE PERSONS NAME:          |
| SINEAD BURROWS / RICHARD ENITCKNAP |



| Item ID                           | Item Description           | Make And Model | Serial Number                              | Item Location | Class | Watts (W) | Rating (A) | Fuse Size | TEST              |                         |                               |                  | Test Engineers Comments: |                |
|-----------------------------------|----------------------------|----------------|--------------------------------------------|---------------|-------|-----------|------------|-----------|-------------------|-------------------------|-------------------------------|------------------|--------------------------|----------------|
|                                   |                            |                |                                            |               |       |           |            |           | Visual Inspection | Earth Continuity (ohms) | Insulation Resistance (Mohms) | Functional Check |                          | Pass or Fail   |
| 48                                | Blue Frail 4 Gang switches | SW 6           | N/A                                        | Top office    | 1     | 300       | 13         | 13        | Pass              | 0.56                    | 794.44                        | Pass             | Pass                     | Tested at 500v |
| 49                                | 16 extension lead flexon   | flexon         | N/A                                        | Top office    | 1     | 300       | 13         | 13        | Pass              | 0.24                    | 794.44                        | Pass             | Pass                     | Tested at 500v |
| 50                                | PC Monitor Black 6         | PC11           | <del>60133755</del><br><del>60133755</del> | Top office    | 1     | 180       | 5          | 5         | Pass              | 0.34                    | 794.44                        | Pass             | Pass                     | Tested at 250v |
| 51                                | PC Monitor Black 7         | PC11           | J54242                                     | Top office    | 1     | 180       | 5          | 5         | Pass              | 0.27                    | 794.44                        | Pass             | Pass                     | Tested at 250v |
| 52                                | Printer SAMSUNG compact    | PC11           | D10V                                       | Top office    | 1     | 470       | 5          | 5         | Pass              | 0.22                    | 794.44                        | Pass             | Pass                     | Tested at 250v |
| 53                                | White office desk fan      | Teststation    | F436-165                                   | Top office    | 2     | 30        | 3          | 3         | Pass              | 0.10                    | 794.44                        | Pass             | Pass                     | Tested at 500v |
| 54                                | White office Printer       | HP -office     | 7740                                       | Top office    | 2     | 400       | 5          | 5         | Pass              | 0.10                    | 794.44                        | Pass             | Pass                     | Tested at 250v |
| 55                                | White microwave. Pings     | MWM17CUF       | N/A                                        | Top office    | 1     | 1150      | 13         | 13        | Pass              | 0.94                    | 794.44                        | Pass             | Pass                     | Tested at 500v |
| 56                                | White kettle               | Elegantio      | E10002                                     | Top kitchen   | 1     | 2200      | 13         | 13        | Pass              | 0.25                    | 794.44                        | Pass             | Pass                     | Tested at 250v |
| 57                                | White fridge/freezer       | ELEGANTIO      | Essentials                                 | Top kitchen   | 1     |           | 13         | 13        | Pass              | 0.54                    | 794.44                        | Pass             | Pass                     | Tested at 500v |
| 58                                | White radio                | Philips        | AZ1055                                     | Reception     | 2     | 15        | 3          | 3         | Pass              | 0.10                    | 794.44                        | Pass             | Pass                     | Tested at 250v |
| 59                                | Television 40cm from white | Teststation    | DELUCIA                                    | Reception     | 2     | 30        | 3          | 3         | Pass              | 0.10                    | 794.44                        | Pass             | Pass                     | Tested at 250v |
| 60                                | White floor fan            | Kingsstar      | 2018W48                                    | Reception     | 2     |           | 3          | 3         | Pass              | 0.10                    | 794.44                        | Pass             | Pass                     | Tested at 250v |
| 61                                | White toaster              | De'Longhi      | SD11651                                    | Top kitchen   | 1     | 1200      | 5          | 5         | Pass              | 0.37                    | 794.44                        | Pass             | Pass                     | Tested at 250v |
| 62                                | Kingsstar floor fan white  | Kingsstar      | 2018W46                                    | Reception     | 2     |           | 3          | 3         | Pass              | 0.10                    | 794.44                        | Pass             | Pass                     | Tested at 250v |
| TOTAL NUMBER OF APPLIANCES: [ 1 ] |                            |                |                                            |               |       |           |            |           |                   |                         |                               |                  |                          |                |