MHR

SALTASH TOWN COUNCIL
SERVICE DELIVERY DEPARTMENT

IN SERVICE TESTING AND INSPECTION (PAT TESTING)



DATE:
MARCH 25
ENGINEERS NAME & SIGNATURE:
Josh Floyd
CONTACT INFORMATION
01752 844846

TEST EQUIPMENT/MODEL:
MEGGER PAT150R (131479)
SERIAL NUMBER:
SN 1003-428
CALIBRATION DATE:

CUSTOMERS NAME:
SALTASH TOWN COUNCIL
SITE ADDRESS:
RESPONIBLE PERSONS NAME:
SINEAD BURROWS / RICHARD ENTICKNAP

Item ID	Item Descripton	Make And Model	Serial Number	Item Location	Class	Watts (W)	Rating (A)	Fuse Size	TEST: Visual Inspection	TEST: Earth Continuity (Ohms)	TEST: Insulation Resistance (Mohms)	TEST: Functional Check	TEST: Pass or Fail	Test Engineers Comments:
01	Ensign 30 Vacuum	Ensign	NA	MHR	2	890	13	13	Pass	0.10	>999	Pass	Pass	Tested at 500v
02	Bush white fridge	Bush	M50S5WF	Kitchen	1		5	5	Pass	0.79	>999	Pass	Pass	Tested at 250v
03	Black RH Microwave	Russell Hobbs	RHMD7	Kitchen	1	1150	13	13	Pass	0.43	>999	Pass	Pass	Tested at 250v
04	Black Cookworks Kettle	Cookworks	WK5254AM	Kitchen	1	3000	13	13	Pass	0.52	>999	Pass	Pass	Tested at 250v

TOTAL NUMBER OF APPLIANCES: [ ]