

WGS POWER & LIGHTING LTD

ANCHOR POINT TESTING

Test Certificate

Customer: SALTASH TOWN COUNCIL.

This is to certify as detailed below were proof load tested as specified to BS5080: 1993 (Methods of test for structural fixings in concrete and masonry, Part 1, Tensile Loads)

Details of installation: ZIG ZAG, CROSS STREET, WATERSIDE COLUMNS

Site Address VARIOUS WITHIN TOWN

Quantity: 22

Pull-out Force Applied: 3kn

Date of Testing: 3/10/2023

Suggested Latest Re-test Date: 2/10/2024

Results: AS ATTACHED ALL PASSED AT WIRE IN GOOD CONDITION

Notes: LOOKS NEWISH, GRIPPLE JOINTS USED IN SOME PLACES

Tests are conducted on individual eyebolts fully screwed or bolted through their own individual anchors. Subsequent removal and/or replacement of any bolt by unauthorised personnel invalidates the test certificate and renders the installation unfit for use.


The re-test date entered on this certificate is provided for guidance purposes only and complies with CSS standard requirements. This also requires a visual check of soundness prior to each use and by cleaning and regular maintenance.


The eyebolts tested are for decoration use only and tested to the loads stated above.


The client must ensure that the loads imposed do not exceed that certificate. Under no circumstances are they to be used for lifting tackle, hoisting, safety harnesses etc. Customers are expressly requested to draw attention to all potential operatives and staff to this fact.


In the event of an eyebolt working loose, the client should report this to us immediately and withdraw the eyebolt from use until checked.

These tests are carried out in accordance with our standard terms and conditions.

Signed: 

Anchor Point Crew Chief: 

Signed: 

Director: 

WGS Power & Lighting LTD

Midge Hall Farm, Royal Wootton Bassett, Swindon, Wiltshire. SN4 8ER

Tel: 01793 840844. Email: info@wgspower.co.uk

www.wgspower.co.uk

Registered in England No. 5340496 VAT No. 718028247

WGS POWER & LIGHTING LTD

LOCATION: **SALTASH**

ANCHOR POINT TEST REPORT

Anchor Point Reference No.	Location	Test Date	Required KN Test	Pass / Fail	Next Test Date
1	WATER SIDE / NO ANCHOR POINT. ALL GRIPPLE JOINTS LOCK OK.			✓	
2	ROOB VISUAL INSPECTION	3/10 23	-	✓	
3	ROOB "	3/10 23	-	✓	
4	RO10 "	3/10 23	-	✓	
5	RO10 "	3/10 23	-	✓	
6	RO12 "	3/10 23	-	✓	
7	RO12 "	3/10 23	-	✓	
8	RO14 "	3/10 23	-	✓	
9	RO14 "	3/10 23	-	✓	
10	RO15 ✓	3/10 23	-	✓	
11	RO15 "	3/10 23	-	✓	
12	RO16 "	3/10 23	-	✓	
13	RO16 "	3/10 23	-	✓	
14	RO18 "	3/10 23	-	✓	
15	RO18 "	3/10 23	-	✓	
16	DOUBLE WIRE END OF FOREST	3/10 23	-	✓	
17	NEXT TO ROOB	3/10 23	-	✓	

Qualified Tester Signature:

Qualified Testers Name:

Date: **3/10/23**

WGS Power & Lighting LTD

Midge Hall Farm, Royal Wootton Bassett, Swindon Wiltshire, SN48ER

Tel: 01793840844 Email: info@wgspower.co.uk www.wgspower.co.uk

Registered in England No: 5340496 VAT No. 718 028247

WGS POWER & LIGHTING LTD

LOCATION: **SALTASH**

ANCHOR POINT TEST REPORT

Anchor Point Reference No.	Location	Test Date	Required KN Test	Pass / Fail	Next Test Date
18	RODG	3/10 23	—	✓	
19	RAILWAY INN	3/10 23	3	✓	
20	SALTASH HERITAGE	3/10 23	3	✓	
21	DENTAL SURGERY	3/10 23	—	✓	
22	" DOUBLES WIRE END OF FOREST (ROUNDAABOUT)	3/10 23	—	✓	

Please note:
 The Waterside catenary wires are not secured with anchor bolts and instead gripple joints have been installed previously. These are sufficient for festoon lighting and bunting, however, nothing heavier than this should be loaded.

Qualified Tester Signature:

Qualified Testers Name:

Date: **3/10/23**